

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements NOT Met for
Hardy County Public Service District
Baker Water System – WV3301613

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Between January 1, 2020 and December 31, 2020, we failed to submit the required samples as indicated below and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the required monitoring and the compliance period.

Required Monitoring	Compliance Period
03, MONITORING, ROUTINE MAJOR VOC Sample Results Not Submitted	1/1/2020 to 12/31/2020

What happened? What is being done?

The Hardy County Public Service District collected the required annual water samples and sent the samples to the laboratory for testing for volatile organic compounds (VOC) however the laboratory did not run the tests within the allotted holding time. The error was not discovered until after the December 31, 2020 deadline. The water testing will be conducted this year as part of our annual water testing.

For more information, please contact Logan Moyers, General Manager at (304) 530-3048 or the Hardy County Public Service District, Post Office Box 900, Moorefield, West Virginia 26836.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

*This is notice is being sent to you by the Hardy County Public Service District - Baker Water System
State Water System ID# WV3301613*

Date Distributed: May 14, 2021